

**TRWA RECOMMENDED 5/8" X 3/4" METER EQUIVALENTS
BASED ON AWWA SPECIFICATIONS AND DESIGN CRITERIA**

| METER SIZE | RECOMMENDED CONTINUOUS RATE OF FLOW | RESIDENTIAL METER EQUIVALENTS |
|-------------------|--|--|
| 5/8" X 3/4" | 10.0 GPM | 1.00 |
| 1" | 25.0 GPM | 2.50 |
| 1 1/2" | 50.0 GPM | 5.00 |
| 2" | 80.0 GPM | 8.00 |
| 3" DISP. | 90.0 GPM | 9.00 |
| 3" CMPD | 160.0 GPM | 16.00 |
| 3" TURB. | 175.0 GPM | 17.50 |
| 4" CMPD | 250.0 GPM | 25.00 |
| 4" TURB. | 300.0 GPM | 30.00 |
| 6" CMPD | 500.0 GPM | 50.00 |
| 6" TURB. | 625.0 GPM | 62.50 |
| 8" CMPD | 800.0 GPM | 80.00 |
| 10" CMPD | 1,150.0 GPM | 115.00 |

NOTE: ALTHOUGH AWWA DOES NOT RECOMMEND A CONTINUOUS FLOW OF GREATER THAN 50 PERCENT FOR DISPLACEMENT AND MULTIJET METERS, METER EQUIVALENTS ARE CALCULATED ON A PROPORTIONAL BASIS AND REMAIN THE SAME REGARDLESS OF ALLOWABLE RATES.